

Updated Total System Demand Response/Price Response Results

							Survey Results	
Date	Characteristics (all response is in MW for HE 17)	Total System- Level DR/PR	Competitive ERS Load*	TDSP Standard Offer Program	4CP/Near 4CP NOIE and Competitive Response	Price Responsive Demand NOIE + Competitive Market	Peak Rebate/ Direct Load Control	
Aug 12	4CP Day	2,223	0	157	2,082	1,865	2	
Aug 13	EEA1, Near CP	2,604	472	19	2,136	2,487	146	
Aug 14	High Prices, High Load	1,068	0	0	946	979	0	
Aug 15	EEA1,Max Prices, High Load	2,114	440	0	1,741	1,489	3	
Aug 16	High Prices	1,135	0	0	0	1,039	95	

- Some ESI IDs participate in multiple programs.
- The total system level DR, eliminates double counting.
- The program-level response reflects response provided by all ESI IDs on the program.
- *ERS Response is limited to load (no generation) and does not include NOIE response which is approximately 35 MW